

Incident Notification

Incident Date: August 14, 2021

Title: **Dangerous Occurrence – Electrical Contact**

Description: While trouble shooting within a pump electrical panel, an electrician inadvertently touched a wire and received an electric shock. The breaker had been opened and closed a number of times during the intervention.

Resolution: The worker reported the incident to a supervisor and was examined by the nurse. The worker was not injured and there was no effect on the environment or other workers. Orano is investigating the circumstances. Provincial and federal regulators were notified.

