

Incident Notification

Incident Date: December 1, 2021

Title: Reportable Radioactive Release on Mill Terrace

Description: The calciner gas wash system was restarted after routine cleaning. Material had loosened during the cleaning process and was discharged from the calciner stack. Approximately 0.7 m³ of radioactive material reported to the mill terrace in the immediate vicinity of the calciner building. There were no workers in the area at the time of the discharge.

Resolution: No effects on health or safety. The material was quickly identified and cleaned up. The effect on the environment is negligible. Provincial and federal regulators were notified and a follow-up report will be submitted to regulators.

